

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Mobile Home Park Inspection - Summary Report

Operation: Finger Lakes Mobile Home Park (ID: 308090)
Facility Name: Finger Lakes Mobile Home Park
Facility Code: 4900686
Facility Address: 3917 Route 96a

To the Attention of:
Victor Mobile Home Parks, Inc. Linda Hannan
784 Old Dutch Road
Victor , NY 14564-

Inspection
Date: MAR 11, 2013 11:02 AM
Inspector: Thomas Scoles (tscoles@co.seneca.ny.us)
Responsible Person: Robert King (email: rking71z28@yahoo.com)

Summary
Number of public health hazards found: 4
Number of public health hazards NOT corrected: 0
Number of other violations found: 1

Each violation that was found is reported below with a description and summary of the requirement.

PUBLIC HEALTH HAZARDS

A public health hazard is any condition that poses an imminent threat to the health or safety of the public. An owner/operator of a regulated facility must immediately correct all public health hazards or take actions to prevent exposure to the hazard.

VIOLETION # 4 WAS OBSERVED 4 TIME(S). PUBLIC HEALTH HAZARD

All or parts of the violation item are IN violation.

Code Requirements

Service equipment properly installed, maintained {17.6 (c)}

Inspector Findings

panel boards for electric meters at lot E,lotG,lotM and lot S need repair.....

GENERAL

VIOLETION # 11 WAS OBSERVED 1 TIME(S).

All or parts of the violation item are IN violation.

Code Requirements

Vehicle/Pedestrian traffic control; emergency vehicle access {17.11(e)(3)}

Inspector Findings

potholes need to be filled in driveway

Additional Information Collected During Inspection

Sewage - Tenant responsible for connecting pipe maintenance; Other Utilities - Tenant responsible for maintenance of connection;

Comments

END of REPORT

[Submit# 103445] FINGER LAKES MOBILE HOME PARK (ID 308090) Inspection# 1001320319