

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection - Summary Report

Operation: MYER FARM DISTILLERS (ID: 851558)

Facility Name: myer farm distillers

Facility Code: MYER

Facility Address:

To the Attention of:

Sanitary Survey

Date: JAN 21, 2015 02:17 PM

Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)

Responsible Person: Joe Myer (email:)

Summary

Number of public health hazards found: 0

Number of public health hazards NOT corrected:

Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - Chlorination; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 2:25pm, from Bathroom CWT; Chlorine residual - 0.59 mg/l, collection time 2:20pm from Bathroom CWT;

Comments

Total Coliform water sample taken Bathroom CWT. Nitrate Water sample taken CWT. Hose Bib vacuum breaker needs to

END of REPORT

[Submit# 127490] MYER FARM DISTILLERS (ID 851558) Inspection# 1001637788