

State Sanitary Code or New York Code of Rules and Regulations

Agricultural Fairgrounds

Statutory authority: Public Health Law, Section 225 or Title 10 NY Code of RR

http://www.health.ny.gov/regulations/nycrr/title_10

These items summarize the sections of the law and/or State Sanitary Code applicable to the inspection. The owner or operator of the facility shall comply with all requirements of the law and/or sanitary code. Violations noted during the inspection will be listed in the Inspection Summary Report.

<u>ITEM NUMBER</u>	<u>GENERAL HEADING</u>	<u>CODE REQUIREMENTS</u>
1	PUBLIC HEALTH HAZARDS	Potable water supply maximum contaminant level not exceeded {7-5.5(b)(1)(i)}
2	PUBLIC HEALTH HAZARDS	Use of approved potable water supply {7-5.5(b)(1)(ii)}
3	PUBLIC HEALTH HAZARDS	Adequate quantity of potable water {7-5.5(b)(1)(iii)}
4	PUBLIC HEALTH HAZARDS	Potable water free from hazardous/toxic chemical contamination {7-5.5(b)(1)(iv)}
5	PUBLIC HEALTH HAZARDS	Adequate disinfection, chlorine residual maintained {7-5.5(b)(1)(v)}
6	PUBLIC HEALTH HAZARDS	Absence of cross connections or other faults in distribution system or plumbing system {7-5.5(b)(1)(vi)}
7	PUBLIC HEALTH HAZARDS	Water supply not affected /contaminated by storage/presence of animal waste {7-5.5(b)(1)(vii)}
8	PUBLIC HEALTH HAZARDS	No inadequately treated sewage accessible to occupants; no contamination of water supply {7-5.5(b)(1)(viii)}
9	PUBLIC HEALTH HAZARDS	Food service provided by owner, no hazards (refer to hazards on DOH-192/35/1611) {7-5.5(b)(1)(ix)}
10	PUBLIC HEALTH HAZARDS	Electrical service, wiring components free from imminent fire or shock hazard {7-5.5(b)(1)(x)}
11	PUBLIC HEALTH HAZARDS	Other {7-5.5(b)(1)(xi)}
12	GENERAL	Valid permit to operate {7-5.3(a)}
13	GENERAL	"Individual in charge" present/immediately available {7-5.4(b)}
14	GENERAL	Training course completed by fairground owner or designee {7-5.4(b)(1)}
15	GENERAL	Written schedule/description of events submitted {7-5.4(d)}
16	GENERAL	Food service, campground and temporary residence facilities NOT operated by an agricultural fairground owner possess a valid permit {7-5.4(e)}
17	GENERAL	Hazard/illness reported as required {7-5.4(f)}
18	GENERAL	Construction/modification - plans approved prior to construction {7-5.7}
19	GENERAL	Adequate surface drainage {7-5.10}
20	GENERAL	Foodservice complies with Subpart 14-1, 14-2, 14-4 (complete and attach DOH 192/35/1611) {7-5.11}
21	CAMPGROUND	Campsites adequately sized, separation/conditions maintained {7-5.8(a)}
22	CAMPGROUND	Electrical service, wiring and fixtures installed, maintained {7-5.8(b)}
23	CAMPGROUND	Overnight occupancy structures which do not meet the definition of a camping unit comply with Subpart 7-1 (complete and attach DOH-1312) {7-5.9}

State Sanitary Code or New York Code of Rules and Regulations

Agricultural Fairgrounds

Statutory authority: Public Health Law, Section 225 or Title 10 NY Code of RR

http://www.health.ny.gov/regulations/nycrr/title_10

These items summarize the sections of the law and/or State Sanitary Code applicable to the inspection. The owner or operator of the facility shall comply with all requirements of the law and/or sanitary code. Violations noted during the inspection will be listed in the Inspection Summary Report.

<u>ITEM NUMBER</u>	<u>GENERAL HEADING</u>	<u>CODE REQUIREMENTS</u>
24	CAMPGROUND	Adequate potable water supply quantity for campground (55gpd/per campsite) {7-5.12(d)(7)(i)}
25	CAMPGROUND	Potable water within 250 ft of all campsites, minimum 1 spigot for each 10 campsites {7-5.12(d)(7)(ii)}
26	CAMPGROUND	Dumping station (1:100 campsites or less) or adequate scavenger system provided and maintained {7-5.13(e)}
27	CAMPGROUND	Toilet facilities - located within 500 ft. of campsites, minimum 4 toilets, 2 per sex {7-5.14(a)(3)}
28	CAMPGROUND	Handwash facilities - ratio (1 handwash facility for every 2 toilets), close proximity to toilets {7-5.14(a)(3)(i)}
29	SEWAGE	Plans submitted for new/modified sewage treatment facilities {7-5.13(a)}
30	SEWAGE	Plans approved prior to construction - work in accordance with approved plans {7-5.13(b)}
31	SEWAGE	Absence of inadequately treated sewage on ground surface {7-5.13(c)}
32	SEWAGE	Privies/portable chemical toilets properly located, constructed, maintained {7-5.13(d)}
33	TOILETS/HANDWASHING	Adequate toilet and handwash facilities provided {7-5.14(a)(1)}
34	TOILETS/HANDWASHING	Handwash facilities - adequate, required locations, maintained {7.5.14(a)(2)}
35	REFUSE/ANIMAL WASTE	Facilities provided, maintained. Temporary storage/collection, refuse and animal waste acceptable. Insects/rodents controlled {7-5.15(a)}
36	REFUSE/ANIMAL WASTE	Written plan submitted/approved for animal waste and refuse handling/storage - Plan updated annually {7-5.15(b)}
37	WATER SUPPLY/DISTRIBUTION SYSTEM	Construction/modification - plans approved prior to construction {7-5.12(d)(3)}
38	WATER SUPPLY/DISTRIBUTION SYSTEM	Interruptions, changes in sources or treatment reported within 24 hrs {7-5.12(d)(4)}
39	WATER SUPPLY/DISTRIBUTION SYSTEM	Distribution system adequate, 20 psi maintained {7-5.12(d)(5)}
40	WATER SUPPLY/DISTRIBUTION SYSTEM	Distribution system capable of providing start -up/booster chlorination {7-5.12(d)(6)(i)}
41	WATER SUPPLY/DISTRIBUTION SYSTEM	Disinfection method approved {7-5.12(d)(6)(ii)}
42	WATER SUPPLY/DISTRIBUTION SYSTEM	Free chlorine residual in distribution system adequate (.2ppm min/4+hrs) actual cl2 _____ppm {7-5.12(d)(6)(iii)}
43	WATER SUPPLY/DISTRIBUTION SYSTEM	On-site disinfection system - equipped w/auxiliary power system {7-5.12(d)(6)(iv)}
44	WATER SUPPLY/DISTRIBUTION SYSTEM	Annual start-up procedure conducted within 15 days of 1st event - report submitted {7-5.12(e)}
45	WATER SUPPLY/DISTRIBUTION SYSTEM	Individual event start-up procedure conducted - report submitted {7-5.12(f)}

State Sanitary Code or New York Code of Rules and Regulations

Agricultural Fairgrounds

Statutory authority: Public Health Law, Section 225 or Title 10 NY Code of RR

http://www.health.ny.gov/regulations/nycrr/title_10

These items summarize the sections of the law and/or State Sanitary Code applicable to the inspection. The owner or operator of the facility shall comply with all requirements of the law and/or sanitary code. Violations noted during the inspection will be listed in the Inspection Summary Report.

<u>ITEM NUMBER</u>	<u>GENERAL HEADING</u>	<u>CODE REQUIREMENTS</u>
46	WATER SUPPLY/DISTRIBUTION SYSTEM	Required monitoring performed; results submitted as required {7-5.12(g)(1)}
47	WATER SUPPLY/DISTRIBUTION SYSTEM	Free chlorine residual measured prior to; daily, during individual events {7-5.12(g)(2)}
48	WATER SUPPLY/DISTRIBUTION SYSTEM	Additional monitoring performed when required {7-5.12(g)(3)}
49	WATER SUPPLY/DISTRIBUTION SYSTEM	Annual plan for system monitoring submitted {7-5.12(g)(4)}
50	WATER SUPPLY/DISTRIBUTION SYSTEM	Sample results analyzed by NYS approved lab {7-5.12(h)}
51	WATER SUPPLY/DISTRIBUTION SYSTEM	System free of cross connections {7-5.12(i)}
52	WATER SUPPLY/DISTRIBUTION SYSTEM	System adequately maintained/supervised {7-5.12(j)}
53	WATER SUPPLY/DISTRIBUTION SYSTEM	Operator - appropriate grade {7-5.12(k)(1)}
54	WATER SUPPLY/DISTRIBUTION SYSTEM	Operation records maintained and submitted {7-5.12(k)(1)(ii)}
55	WATER SUPPLY/DISTRIBUTION SYSTEM	Bulk/bottled water - approved source in accordance with Subpart 5-6 {7-5.12(l)}
56	WATER SUPPLY/DISTRIBUTION SYSTEM	Drinking fountains of sanitary design {7-5.12(m)}
57	NON-PUBLIC WATER SUPPLY	Source water acceptable {7-5.12(c)}
58	NON-PUBLIC WATER SUPPLY	New construction - source location acceptable {7-5.12(d)(1)}
59	NON-PUBLIC WATER SUPPLY	Water source & distribution system protected from contamination; separation distance(s) adequate {7-5.12(d)(2)}