

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection - Summary Report

Operation: The Kountry Stop - water (ID: 754825)
Facility Name: the kountry stop
Facility Code: 49-3568
Facility Address: 4477 Route 96A Geneva, NY 14456

To the Attention of:
TRACY TAYLOR MAYBURRY
1640 AUNKST ROAD
WATERLOO , NY 13165-

Sanitary Survey

Date: APR 14, 2015 03:14 PM
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)
Responsible Person: Kelley Ryan (email: kountrystop@aol.com)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected:
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - None; Source Type - Not indicated; 4- Log Treatment installed - Not indicated; Coliform surveillance sample collected - No ;

Comments

Total Coliform water sample taken utility room CWT. Nitrate water sample taken utility room CWT. Well was evaluated and found in good condition. Ultra Violet disinfection system was found in good condition.

END of REPORT

[Submit# 132638] The Kountry Stop - water (ID 754825) Inspection# 1001654247