

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection - Summary Report

Operation: Waterloo Mennonite School (ID: 308110)
Facility Name: waterloo mennonite school
Facility Code: 49-AC02
Facility Address: 3028 Miller ROAD WATERLOO, NY 13165

To the Attention of:

Sanitary Survey

Date: APR 20, 2015 03:01 PM
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)
Responsible Person: John L. Zimmerman (email:)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected:
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 3:04pm, from boys CWT; Chlorine residual - 0 mg/l, collection time 3:00pm from boys CWT;

Comments

Total Coliform water sample taken Boys CWT. Nitrate water sample taken Boys CWT. Extra bulb and sleeve not on-site. Advised to have on hand at all times. Well was evaluated and found in good condition.

END of REPORT

[Submit# 132938] Waterloo Mennonite School (ID 308110) Inspection# 1001654547