

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection - Summary Report

Operation: Hidden Ponds Campground water (ID: 421824)
Facility Name: hidden ponds campground
Facility Code: 49-8526
Facility Address: 6598 Log City Road ROAD Ovid, NY 14521

To the Attention of:

Sanitary Survey

Date: MAY 20, 2015 11:33 AM
Inspector: Melissa Brand (mbrand@co.seneca.ny.us)
Responsible Person: John Coleman (email:)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected:
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - Chlorination; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time , from bathroom cwt;

Comments

Water sample taken for analysis- T.coliform and Nitrates

END of REPORT

[Submit# 134833] Hidden Ponds Campground water (ID 421824) Inspection# 1001662676