

Seneca County Department of Health  
Environmental Services  
31 Thurber Drive , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us

## Temporary Residence Inspection - Summary Report

Operation: MICROTEL INN & SUITES (ID: 308351 )  
Facility Name: MICROTEL INN & SUITES  
Facility Code: 49-AJ63  
Facility Address: 1966 5 & 20 ROUTE SENECA FALLS, NY 13148

To the Attention of:  
NICK MASSA BLUE STAR DEVELOPMENT,LLC  
PO BOX 807  
SENECA FALLS , NY 13148-

### Inspection

Date: MAY 19, 2015 03:40 PM  
Inspector: Julie Hoster (jhoster@co.seneca.ny.us)  
Responsible Person: elizabeth alamo (email: )

### Summary

Number of public health hazards found: 0  
Number of public health hazards NOT corrected: 0  
Number of other violations found: 1

Each item found in violation is reported below along with the code requirement.

## FIRE SAFETY

ITEM # 27 WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the violation item are IN violation.

### Code Requirements

Exit signs/emergency lighting readily visible, operational, safe path of travel identified {7-1.8(d)}

### Inspector Findings

1 emergency light (outside room 243) was in need of service

### Additional Information Collected During Inspection

### Comments

elevator inspection up to date; sprinkler system and fire extinguishers inspections up to date; routinely treated to prevent insects records readily available at time of inspection; carpets are getting worn in some areas

END of REPORT

[Submit# 134777] MICROTEL INN & SUITES (ID 308351) Inspection# 1001662480