

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection - Summary Report

Operation: Oak Orchard Campground WATER (ID: 308357)
Facility Name: oak orchard campgrounds
Facility Code: 49-0096
Facility Address: ROUTE 89 AT MAYS POINT SAVANNAH, NY 13146

To the Attention of:

Sanitary Survey

Date: MAY 13, 2015 01:37 PM
Inspector: Melissa Brand (mbrand@co.seneca.ny.us)
Responsible Person: Richard Kramer (email:)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected:
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - Chlorination; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 1:40, from spiggott;

Comments

Water sample taken for T.coliform and Nitrate samples these samples will satisfy the second quarter sample requirements.

END of REPORT

[Submit# 134670] Oak Orchard Campground WATER (ID 308357) Inspection# 1001662302