

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us
Campground Inspection - Summary Report

Operation: WATERLOO HARBOR CAMPGROUND (ID: 308424)
Facility Name: WATERLOO HARBOR CAMPGROUND
Facility Code: 49-0235
Facility Address: 1278 WATERLOO-GENEVA ROAD WATERLOO, NY 13165

To the Attention of:
NORBERT HAUSNER RIVERPARK COMMONS WATERLOO, LLC
2099 RIDGE ROAD WEST
ROCHESTER , NY 14626-

Inspection
Date: MAY 05, 2015 02:38 PM
Inspector: Julie Hoster (jhoster@co.seneca.ny.us)
Responsible Person: justin hausner (email:)

Summary
Number of public health hazards found: 0
Number of public health hazards NOT corrected: 0
Number of other violations found: 2

Each item found in violation is reported below along with the code requirement.

ITEM # 52 WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the violation item are IN violation.

Code Requirements

Showers (when provided) adequate, hot/cold water, maintained

Inspector Findings

back shower in ladies room does not have shower head; back shower in men's room does not work

GENERAL

ITEM # 24 WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the violation item are IN violation.

Code Requirements

Campsites - adequately sized {7-3.8}

Inspector Findings

campers in back of park do not have the minimum 10 feet separation distance

Comments

END of REPORT

[Submit# 133829] WATERLOO HARBOR CAMPGROUND (ID 308424) Inspection# 1001659109