

Seneca County Department of Health  
Environmental Services  
31 Thurber Drive , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us

## Swimming Pool Inspection - Summary Report

Operation: CAMP BABCOCK-HOVEY CUB SCOUTS OUTDOOR POOL (ID: 809916 )  
Facility Name: camp babcock-hovey cub scouts  
Facility Code: 49-1322  
Facility Address: 7294 COUNTY ROAD 132 OVID, NY 14521

To the Attention of:

### Inspection

Date: JUL 23, 2015 04:39 PM  
Inspector: Julie Hoster (jhoster@co.seneca.ny.us)  
Responsible Person: Jay Laitenberger (email: )

### Summary

Number of public health hazards found: 0  
Number of public health hazards NOT corrected: 0  
Number of other violations found: 2

Each item found in violation is reported below along with the code requirement.

## GENERAL

ITEM # 50 WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the violation item are IN violation.

### Code Requirements

Bathhouse/Toilet Facilities Adequate, Clean, Ventilated, Warm Water, Soap, Hand Drying Facilities Provided, Refuse Storage, Disposal {6-1.14, 6-1.15}

### Inspector Findings

facilities old difficult to clean

## RECORDS/SIGNS

ITEM # 20 WAS FOUND IN VIOLATION 1 TIME(S).

Part or parts of the violation item were observed to be in violation which were corrected at the time of inspection.

### Code Requirements

Regulations Posted - Capacity, Spa Warning, White Water Slide {6-1.24(c), 6-1.20(c), 6-1.25(e), 6-1.28(d)}

### Inspector Findings

pool signs of inadequate size; hours not posted

---

Additional Information Collected During Inspection

Free chlorine/bromine - 3 mg/L; PH - 7.2; Total alkalinity - 80 mg/L; Calcium hardness - 170 mg/L; Temporary Residence/Campground - No; Homeowner exemption - No;

Comments

---

END of REPORT

[Submit# 142613] CAMP BABCOCK-HOVEY CUB SCOUTS OUTDOOR POOL (ID 809916) Inspection# 1001681911