

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection - Summary Report

Operation: Junius Ponds Cabins & Campgrounds (ID: 308153)
Facility Name: junius ponds cabins/campground llc
Facility Code: 49-AJ82
Facility Address: 1475 WEST TOWNLINE ROAD PHELPS, NY 14532

To the Attention of:

Sanitary Survey

Date: JUL 29, 2015 02:06 PM
Inspector: Melissa Brand (mbrand@co.seneca.ny.us)
Responsible Person: Elizabeth White (email:)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected:
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - Chlorination; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 2:10 pm, from womens Bathroom CWT;

Comments

END of REPORT

[Submit# 143504] Junius Ponds Cabins & Campgrounds (ID 308153) Inspection# 1001683919