

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Swimming Pool Inspection - Summary Report

Operation: SNED-ACRES FAMILY CAMPGROUNDS POOL (ID: 583637)
Facility Name: SNED-ACRES FAMILY CAMPGROUND
Facility Code: 49-0197
Facility Address: 6590 SOUTH CAYUGA LAKE ROAD OVID, NY 14521

To the Attention of:
LYNN E SNEDAKER
6590 SOUTH CAYUGA LAKE ROAD
OVID , NY 14521-

Inspection

Date: JUL 07, 2015 11:55 AM
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)
Responsible Person: Lynn Snedaker (email: info@sned'acres.com)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected: 0
Number of other violations found: 3

Each item found in violation is reported below along with the code requirement.

POOL OPERATION, MAINTENANCE & SUPERVISION

ITEM # 23 WAS FOUND IN VIOLATION 1 TIME(S).

Violation Item was not applicable/reviewed/evaluated/observed at the time of inspection.

Code Requirements

Lifesaving Equipment Adequate/Accessible, Lifeguard Chairs {6-1.23(b)}

Inspector Findings

Rope around throwable device is not adequate.

ITEM # 36 WAS FOUND IN VIOLATION 1 TIME(S).

Violation Item was not applicable/reviewed/evaluated/observed at the time of inspection.

Code Requirements

Overflow System/ Skimmer - Weirs, Valves, Baskets Maintained {6-1.10(g), (h)}

Inspector Findings

Cover to skimmers were not secure.

RECORDS/SIGNS

ITEM # 18 WAS FOUND IN VIOLATION 1 TIME(S).

Violation Item was not applicable/reviewed/evaluated/observed at the time of inspection.

Code Requirements

Pool Safety Plan Developed/Implemented/Updated {6-1.23(c)}

Inspector Findings

2 year safety plan update has not been returned to the Seneca County Environmental Health Department.

Additional Information Collected During Inspection

Pool/Spa water temperature - 82 degrees Farenheight; Free chlorine/bromine - 1.57 mg/L; Combined chlorine - 3 mg/L; PH - 7.4; Total alkalinity - 100 mg/L; Calcium hardness - 200 mg/L; Supervision level - IV; Temporary Residence/Campground - Yes; Homeowner exemption - No;

Comments

No bathers present during the inspection. Weirs are missing on skimmers.

END of REPORT

[Submit# 139341] SNED-ACRES FAMILY CAMPGROUNDS POOL (ID 583637) Inspection# 1001674672