

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us
Swimming Pool Inspection - Summary Report

Operation: VINCE'S PARK (ID: 308515)
Facility Name: VINCE'S PARK
Facility Code: 49-AA98
Facility Address: CORNER OF ROUTES 318 & 5&20 SENECA FALLS, NY 13148

To the Attention of:
JIM SPINA
35 WATER ST.
SENECA FALLS , NY 13148-

Inspection
Date: JUL 27, 2015 04:20 PM
Inspector: Julie Hoster (jhoster@co.seneca.ny.us)
Responsible Person: Kevin Korzeniewski (email:)

Summary
Number of public health hazards found: 0
Number of public health hazards NOT corrected: 0
Number of other violations found: 4

Each item found in violation is reported below along with the code requirement.

POOL OPERATION, MAINTENANCE & SUPERVISION

ITEM # 25 WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the violation item are IN violation.

Code Requirements

Deck Unobstructed, Clean, No Standing Water, Glass Prohibited {6-1.10(j)}

Inspector Findings

cones all around deck to protect swimmers from injuring toes pose hazard (tripping); this is a temporary fix

RECORDS/SIGNS

ITEM # 18 WAS FOUND IN VIOLATION 1 TIME(S).

Part or parts of the violation item were observed to be in violation which were corrected at the time of inspection.

Code Requirements

Pool Safety Plan Developed/Implemented/Updated {6-1.23(c)}

Inspector Findings

safety plan needed to be updated to include procedures followed with only one lifeguard on duty

ITEM # 20 WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the violation item are IN violation.

Code Requirements

Regulations Posted - Capacity, Spa Warning, White Water Slide {6-1.24(c), 6-1.20(c), 6-1.25(e), 6-1.28(d)}

Inspector Findings

signage a minimum of 36" x24" not present at time of inspection; signage must state pool capacity; the hours the pool is open; glass containers are prohibited; and no pollution of pool; and no pollution of pool signs must be in restrooms and office these do not have to be same size

SUPERVISION/STAFF

ITEM # 56 WAS FOUND IN VIOLATION 1 TIME(S).

Part or parts of the violation item were observed to be in violation which were corrected at the time of inspection.

Code Requirements

Adequate Bather Surveillance - Positioning, Number of Staff, Staff not Distracted {6-1.23(a)(4)-(7)}

Inspector Findings

an operational review/ training with NYSDOH determined pool must have certain areas closed off to operate with only one life guard. single lifeguard cannot be on the peninsula/island;

Additional Information Collected During Inspection

Free chlorine/bromine - 1 mg/L; PH - 7.8; Supervision level - IIb; Temporary Residence/Campground - No; Homeowner exemption - No;

Comments

SCDOH has proper verbiage for signage and will forward to operator pool is borderline > 7.8 pH; pH > than 7.8 must maintain a CI residual of a minimum of 1.5 CI at all times; if pH is = or <7.8 a residual of .6 must be maintained

END of REPORT

[Submit# 142957] VINCE'S PARK (ID 308515) Inspection# 1001683444