

Seneca County Department of Health  
Environmental Services  
31 Thurber Drive , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us  
Swimming Pool Inspection - Summary Report

Operation: Holiday Inn Outdoor Pool (ID: 308305 )  
Facility Name: HOLIDAY INN  
Facility Code: 49-1365  
Facility Address: 2468 414 ROUTE WATERLOO, NY 13165

To the Attention of:  
SERVUS HOTEL GROUP WATERLOO LLC  
6731 Professional Pkwy W. Suite 100  
SARASOTA , FL 34240-8491

Inspection  
Date: AUG 05, 2015 02:36 PM  
Inspector: Melissa Brand (mbrand@co.seneca.ny.us)  
Responsible Person: Kenny Arnold (email: )

Summary  
Number of public health hazards found: 0  
Number of public health hazards NOT corrected: 0  
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Free chlorine/bromine - 1.58 mg/L; PH - 7.0; Total alkalinity - 50 mg/L; Calcium hardness - 370 mg/L; Temporary Residence/Campground - No; Homeowner exemption - No;

Comments

END of REPORT

[Submit# 144898] Holiday Inn Outdoor Pool (ID 308305) Inspection# 1001686760