

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us
Swimming Pool Inspection - Summary Report

Operation: HOLIDAY INN SPA (ID: 308307)
Facility Name: HOLIDAY INN
Facility Code: 49-1365
Facility Address: 2468 414 ROUTE WATERLOO, NY 13165

To the Attention of:
SERVUS HOTEL GROUP WATERLOO LLC
6731 Professional Pkwy W. Suite 100
SARASOTA , FL 34240-8491

Inspection
Date: AUG 05, 2015 03:01 PM
Inspector: Melissa Brand (mbrand@co.seneca.ny.us)
Responsible Person: Kenny Arnold (email:)

Summary
Number of public health hazards found: 0
Number of public health hazards NOT corrected: 0
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Pool/Spa water temperature - 102 degrees Farenheight; Free chlorine/bromine - 3.0 mg/L; PH - 7.8; Total alkalinity - 30 mg/L; Calcium hardness - 110 mg/L; Temporary Residence/Campground - No; Homeowner exemption - No;

Comments

END of REPORT

[Submit# 144902] HOLIDAY INN SPA (ID 308307) Inspection# 1001686768