

Seneca County Department of Health  
Environmental Services  
31 Thurber Drive , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us  
Public Water Supply Inspection - Summary Report

Operation: SUZANNE FINE REGIONAL CUISINE WATER (ID: 443809 )  
Facility Name: suzanne fine regional cuisine  
Facility Code: 49-9013  
Facility Address: 9013 414 ROUTE LODI, NY 14860

To the Attention of:

Sanitary Survey

Date: AUG 04, 2015 02:02 PM  
Inspector: Melissa Brand (mbrand@co.seneca.ny.us)  
Responsible Person: Robert Stack (email: )

Summary

Number of public health hazards found: 0  
Number of public health hazards NOT corrected:  
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - Chlorination; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 2:02 pm, from Kitchen CWT; Chlorine residual - .27 mg/l, collection time from ;

Comments

END of REPORT

[Submit# 144654] SUZANNE FINE REGIONAL CUISINE WATER (ID 443809) Inspection# 1001686192