

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection - Summary Report

Operation: THIRSTY OWL WINE COMPANY, INC. ONSITE WATER SUPPLY (ID: 506519)

Facility Name: thirsty owl wine company, inc.

Facility Code: 49-05805

Facility Address: 6799 ELM BEACH ROAD OVID, NY 14521

To the Attention of:

Sanitary Survey

Date: AUG 12, 2015 01:14 PM

Inspector: Melissa Brand (mbrand@co.seneca.ny.us)

Responsible Person: Jon Cupp (email:)

Summary

Number of public health hazards found: 0

Number of public health hazards NOT corrected:

Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Ground water under the direct influence of surface water; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 1:14, from Tasting room CWT; Chlorine residual - na mg/l, collection time from ;

Comments

Installing larger UV unit Installing filtration in parallel with what is already existing Current UV light will be installed at tasting room as secondary to the larger Second softening unit being installed

END of REPORT

[Submit# 146245] THIRSTY OWL WINE COMPANY, INC. ONSITE WATER SUPPLY (ID 506519) Inspection# 1001689973