

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection - Summary Report

Operation: Three brothers Winery WATER (ID: 587071)
Facility Name: three brothers winery estates llc
Facility Code: 49-cc01
Facility Address: 623 LERCH ROAD WATERLOO, NY 13165

To the Attention of:

Sanitary Survey

Date: AUG 12, 2015 10:14 AM
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)
Responsible Person: Justin Paolicelli (email:)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected:
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 10:15pm, from Kitchen CWT; Chlorine residual - 0 mg/l, collection time 10:16am from Kitchen CWT;

Comments

Total Coliform water sample taken kitchen CWT. Nitrate water sample taken kitchen CWT. UV light in Stoney Lonesome and Bag Dare inspected and found in good condition. Well was evaluated and found in good condition.

END of REPORT

[Submit# 146052] Three brothers Winery WATER (ID 587071) Inspection# 1001689401