

Seneca County Department of Health  
Environmental Services  
31 Thurber Drive , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us  
Swimming Pool Inspection - Summary Report

Operation: NYCC INDOOR POOL (ID: 308322 )  
Facility Name: NEW YORK CHIROPRACTIC COLLEGE  
Facility Code: 49-AA67  
Facility Address: 2360 RT. 89 PO BOX 800

To the Attention of:  
NY CHIROPRACTIC COLLEGE TARA L. FICCAGLIA  
DEPT. OF RECREATIONAL SERVICES 2360 NYS ROUTE 89  
SENECA FALLS , NY 13148-

Inspection  
Date: NOV 05, 2015 12:09 PM  
Inspector: Melissa Brand (mbrand@co.seneca.ny.us)  
Responsible Person: Rhett Ticconi  
(email: )

Summary  
Number of public health hazards found: 0  
Number of public health hazards NOT corrected: 0  
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Pool/Spa water temperature - 81 degrees Fahrenheit; Flow meter reading (gpm) - 526; Free chlorine/bromine - 3.0 mg/L; PH - 7.6; Total alkalinity - 40 mg/L; Supervision level - IIa; Temporary Residence/Campground - No; Homeowner exemption - No;

Comments

END of REPORT

[Submit# 157992] NYCC INDOOR POOL (ID 308322) Inspection# 1001765629