

Seneca County Department of Health  
Environmental Services  
31 Thurber Drive , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us

## Public Water Supply Inspection -- Summary Report

Operation: Caywood Vineyard (ID: 859196 )  
Facility Name: Caywood Vineyard  
Facility Code: 49agm  
Facility Address: 9666 414 ROUTE Lodi, NY 14860

To the Attention of:

### Sanitary Survey

Date: JUN 21, 2016 02:56 PM  
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)  
Responsible Person: Peggy Bond  
(email: )

### Summary

Number of public health hazards found: 0  
Number of public health hazards NOT corrected:  
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

### Code Requirements

### Inspector Findings

---

### Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 3:10pm, from Men's Lave; Chlorine residual - 0 mg/l, collection time 3:00pm from Men's Lave;

### Comments

Total Coliform water sample taken  
Nitrate water sample taken  
UV disinfection system and well were inspected and found in good condition.

---

END of REPORT

[Submit# 206157] Caywood Vineyard (ID 859196) Inspection# 1001835529