

Seneca County Department of Health  
Environmental Services  
31 Thurber Drive , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us

## Public Water Supply Inspection -- Summary Report

Operation: Seneca Meadows Education Center (ID: 693239 )  
Facility Name: Seneca Meadows Education Center  
Facility Code: 49-4565  
Facility Address: 414 ROUTE Seneca Falls, NY 13148

To the Attention of:

### Sanitary Survey

Date: JUN 08, 2016 02:09 PM

Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)

Responsible Person: David Pannucci

(email: David.pannucci@progressivewaste.com )

### Summary

Number of public health hazards found: 0

Number of public health hazards NOT corrected:

Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

### Code Requirements

### Inspector Findings

---

### Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 2:10pm, from classroom CWT; Chlorine residual - 0.70 mg/l, collection time 2:13pm from classroom CWT;

### Comments

New water operator Dave Pannucci trained.

Total Coliform water sample taken.

Nitrate water sample taken.

UV and well inspected and found in good condition.

---

END of REPORT