

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us
Campground Inspection -- Summary Report

Operation: SNED-ACRES FAMILY CAMPGROUNDS (ID: 308227)
Facility Name: SNED-ACRES FAMILY CAMPGROUND
Facility Code: 49-0197
Facility Address: 6590 SOUTH CAYUGA LAKE ROAD OVID, NY 14521

To the Attention of:
LYNN E SNEDAKER
6590 SOUTH CAYUGA LAKE ROAD
OVID , NY 14521-

Inspection

Date: JUN 03, 2016 10:36 AM
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)
Responsible Person: Lori Lavine
(email:)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected: 0
Number of other violations found: 1

Each item found in violation is reported below along with the code requirement.

WATER SUPPLY - GENERAL

ITEM # 40 WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the violation item are IN violation.

Code Requirements

Campground Public Water System - complies w/ Subpart 5-1

Inspector Findings

No chlorine residual found in the external distribution system throughout the campground. Owner stated he will increase chlorine residual.

Additional Information Collected During Inspection

Comments

END of REPORT

[Submit# 201397] SNED-ACRES FAMILY CAMPGROUNDS (ID 308227) Inspection# 1001829410