

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Swimming Pool Inspection -- Summary Report

Operation: Babcock Hovey - Outdoor Pool (ID: 308214)
Facility Name: BABCOCK-HOVEY BSA
Facility Code: 49-0019
Facility Address: 7294 COUNTY ROAD 132 ROAD OVID, NY 14521

To the Attention of:
STEVE HOITT SENECA WATERWAYS COUNCIL, BSA
2320 BRIGHTON HENRIETTA TOWNLINE RD
ROCHESTER , NY 14623-

Pre-op Inspection

Date: JUL 01, 2016 03:06 PM
Inspector: Julie Hoster (jhoster@co.seneca.ny.us)
Responsible Person: Jay Laitenberger
(email:)

Summary

Number of public health hazards found: 2
Number of public health hazards NOT corrected: 0
Number of other violations found: 4

Each item found in violation is reported below along with the code requirement.

PUBLIC HEALTH HAZARDS

A public health hazard is any condition that poses an imminent threat to the health or safety of the public. An owner/operator of a regulated facility must immediately correct all public health hazards or take actions to prevent exposure to the hazard.

ITEM # 7 WAS FOUND IN VIOLATION 1 TIME(S). PUBLIC HEALTH HAZARD

Part or parts of the violation item were observed to be in violation which were corrected at the time of inspection.

Code Requirements

Lifesaving Equipment Present at Pool Deck {6-1.4(b)(8)}

Inspector Findings

no equipment on pool deck

ITEM # 8 WAS FOUND IN VIOLATION 1 TIME(S). PUBLIC HEALTH HAZARD

All or parts of the violation item are IN violation.

Code Requirements

Pool Bottom Visible {6-1.4(b)(9)}

Inspector Findings

pool cloudy could not see bottom CORRECTED: no swimming until water clears

FILTER ROOM & EQUIPMENT

ITEM # 49 WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the violation item are IN violation.

Code Requirements

Chemicals Approved, Proper Storage/Handling/Labeling {6-1.11(c)(1)-(4), (d)}

Inspector Findings

goggles needed next to chlorine fill

GENERAL

ITEM # 50 WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the violation item are IN violation.

Code Requirements

Bathroom/Toilet Facilities Adequate, Clean, Ventilated, Warm Water, Soap, Hand Drying Facilities Provided, Refuse Storage, Disposal {6-1.14, 6-1.15}

Inspector Findings

no soap in showers; bathrooms unclean

POOL OPERATION, MAINTENANCE & SUPERVISION

ITEM # 24 WAS FOUND IN VIOLATION 1 TIME(S).

Part or parts of the violation item were observed to be in violation which were corrected at the time of inspection.

Code Requirements

Pool Fenced, Self-Closing/Self Latching Gates or Doors {6-1.16}

Inspector Findings

Gate does not self closing when pulled open; gate will automatically close when pushed open

ITEM # 34 WAS FOUND IN VIOLATION 1 TIME(S).

Part or parts of the violation item were observed to be in violation which were corrected at the time of inspection.

Code Requirements

Water Quality; Pool Clarity, Bottom/Slides Clean, Water Surface {6-1.19, 6-1.10(k)}

Inspector Findings

water is not clear

Additional Information Collected During Inspection

Free chlorine/bromine - 3 mg/L; PH - 7.2; Total alkalinity - 80 mg/L; Calcium hardness - 150 mg/L; Temporary Residence/Campground - No; Homeowner exemption - No;

Comments

SCDOH will allow pool to open after water clears and the grate at the bottom of pool can be easily seen. The Camp and Aquatics Director will confirm the clarity of the pool. SCDOH will view pool as weekend progresses. SCDOH will confirm by 07/072016

END of REPORT

[Submit# 209378] Babcock Hovey - Outdoor Pool (ID 308214) Inspection# 1001840367