

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection -- Summary Report

Operation: CAYUGA LAKE CREAMERY WATER SUPPLY (ID: 499244)
Facility Name: CAYUGA LAKE CREAMERY
Facility Code: 49-9492
Facility Address: 8421 ROUTE 89 INTERLAKEN, NY 14847

To the Attention of:

Sanitary Survey

Date: JUL 18, 2016 02:48 PM

Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)

Responsible Person: Erin Barr

(email:)

Summary

Number of public health hazards found: 0

Number of public health hazards NOT corrected:

Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - Chlorination; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 2:35pm, from Kitchen CWT; Chlorine residual - 1.12 mg/l, collection time 2:40pm from Kitchen CWT;

Comments

Total Coliform water sample taken.

Nitrate water sample taken.

END of REPORT

[Submit# 214765] CAYUGA LAKE CREAMERY WATER SUPPLY (ID 499244) Inspection# 1001847175