

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection -- Summary Report

Operation: FINGER LAKES CIDER HOUSE water (ID: 929513)
Facility Name: FINGER LAKES CIDER HOUSE
Facility Code: 49-6523
Facility Address: 4017 HICKOK ROAD INTERLAKEN, NY 14847

To the Attention of:

Sanitary Survey

Date: JUL 20, 2016 03:16 AM
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)
Responsible Person: Garret Miller
(email:)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected:
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

PUBLIC HEALTH HAZARD

VIOLATION OF 5-1.30(a) WAS OBSERVED. (# 7)

Part or parts of the violation item were observed to be in violation which were corrected at the time of inspection.

Code Requirements

5-1.30(a)(b) [ND] Disinfection of a groundwater source. CI and UV equipment is operating as designed. If UV is working, indicator light is On, intensity meter is >70%.

Inspector Findings

Public Health Hazard - Ultra Violet disinfection system had and efficiency reading of 52%. Owner contacted Lowes soft water service, Inc. to repair.

Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 3:15pm, from basement sink; Chlorine residual - 0 mg/l, collection time 3:20pm from basement sink;

Comments

Total Coliform water sample taken.
Nitrate water sample taken.
Advised to install a barrier around well located at edge of parking lot to protect well from being damaged.

END of REPORT

[Submit# 216085] FINGER LAKES CIDER HOUSE water (ID 929513) Inspection# 1001848754