

Seneca County Department of Health  
Environmental Services  
31 Thurber Drive , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us  
Campground Inspection -- Summary Report

Operation: JUNIUS PONDS CABINS/CAMPGROUND (ID: 308152 )  
Facility Name: JUNIUS PONDS CABINS/CAMPGROUND  
Facility Code: 49-AJ82  
Facility Address: 1475 WEST TOWNLINE ROAD PHELPS, NY 14532

To the Attention of:  
ERIC DADSON  
1475 WEST TOWNLINE ROAD  
PHELPS , NY 14532-

Re-Inspection

Date: JUL 22, 2016 03:35 PM  
Inspector: Melissa Brown (mbrand@co.seneca.ny.us)  
Responsible Person: mailed  
(email: )

Summary

Number of public health hazards found: 1  
Number of public health hazards NOT corrected: 0  
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

**PUBLIC HEALTH HAZARDS**

A public health hazard is any condition that poses an imminent threat to the health or safety of the public. An owner/operator of a regulated facility must immediately correct all public health hazards or take actions to prevent exposure to the hazard.

**ITEM # 7 WAS FOUND IN VIOLATION 1 TIME(S). PUBLIC HEALTH HAZARD**

All or parts of the violation item are IN violation.

Code Requirements

Absence of cross connections - potable water supply {7-3.5(b)(1)(vii)}

Inspector Findings

Hydro flush used on one camper. All other campers were said to be checked by campground owner after initial inspection. Hydroflush at Ruiz Blvd.

Additional Information Collected During Inspection

Comments

END of REPORT

[Submit# 217830] JUNIUS PONDS CABINS/CAMPGROUND (ID 308152) Inspection# 1001850744