

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection -- Summary Report

Operation: Lameroux Landing (ID: 308848)
Facility Name: Lameroux Landing
Facility Code: ag-06
Facility Address: Rt. 414

To the Attention of:

Mark Wagner
9224 Rt. 414
Iodi , ny 14860-

Sanitary Survey

Date: JUL 11, 2016 02:59 PM
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)
Responsible Person: Brenda Clawson
(email: brendac@lamoreauxwine.com)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected:
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 2:06pm, from Break room CWT; Chlorine residual - 0 mg/l, collection time 2:10pm from Break room CWT;

Comments

Total Coliform and Nitrate water sample taken.
No disinfection system in place. Lamoreaux is on a disinfection waiver.

END of REPORT

[Submit# 212217] Lameroux Landing (ID 308848) Inspection# 1001844033