

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Swimming Pool Inspection -- Summary Report

Operation: SNED-ACRES FAMILY CAMPGROUNDS POOL (ID: 583637)
Facility Name: SNED-ACRES FAMILY CAMPGROUND
Facility Code: 49-0197
Facility Address: 6590 SOUTH CAYUGA LAKE ROAD OVID, NY 14521

To the Attention of:
LYNN E SNEDAKER
6590 SOUTH CAYUGA LAKE ROAD
OVID , NY 14521-

Inspection

Date: JUL 12, 2016 01:08 PM
Inspector: Julie Hoster (jhoster@co.seneca.ny.us)
Responsible Person: William Levine
(email:)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected: 0
Number of other violations found: 1

Each item found in violation is reported below along with the code requirement.

RECORDS/SIGNS

ITEM # 20 WAS FOUND IN VIOLATION 1 TIME(S).

Part or parts of the violation item were observed to be in violation which were corrected at the time of inspection.

Code Requirements

Regulations Posted - Capacity, Spa Warning, White Water Slide {6-1.24(c), 6-1.20(c), 6-1.25(e), 6-1.28(d)}

Inspector Findings

no signs found in the restrooms or office stating POLLUTION OF POOL PROHIBITED. URINATING, DISCHARGE of FECAL MATTER, EXPECTORATING or BLOWING THE NOSE IN ANY SWIMMING POL IS PROHIBITED

Additional Information Collected During Inspection

Pool/Spa water temperature - 80 degrees Fahrenheit; Flow meter reading (gpm) - 60; Free chlorine/bromine - .94 mg/L; PH - 7.4; Total alkalinity - 90 mg/L; Calcium hardness - 270 mg/L; Supervision level - IV; Temporary Residence/Campground - Yes; Homeowner exemption - No;

Comments

END of REPORT

[Submit# 212390] SNED-ACRES FAMILY CAMPGROUNDS POOL (ID 583637) Inspection# 1001844275