

Seneca County Department of Health  
Environmental Services  
31 Thurber Drive , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us  
Swimming Pool Inspection -- Summary Report

Operation: VINCE'S PARK (ID: 308515 )  
Facility Name: VINCE'S PARK  
Facility Code: 49-AA98  
Facility Address: CORNER OF ROUTES 318 & 5&20 SENECA FALLS, NY 13148

To the Attention of:  
KEVIN KORZENIEWSKI  
35 WATER ST.  
SENECA FALLS , NY 13148-

Inspection

Date: JUN 28, 2016 02:42 PM  
Inspector: Julie Hoster (jhoster@co.seneca.ny.us)  
Responsible Person: KEVIN KORZENIEWSKI  
(email: )

Summary

Number of public health hazards found: 0  
Number of public health hazards NOT corrected: 0  
Number of other violations found: 2

Each item found in violation is reported below along with the code requirement.

RECORDS/SIGNS

ITEM # 20 WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the violation item are IN violation.

Code Requirements

Regulations Posted - Capacity, Spa Warning, White Water Slide {6-1.24(c), 6-1.20(c), 6-1.25(e), 6-1.28(d)}

Inspector Findings

pool capacity

SUPERVISION/STAFF

ITEM # 56 WAS FOUND IN VIOLATION 1 TIME(S).

Part or parts of the violation item were observed to be in violation which were corrected at the time of inspection.

Code Requirements

Adequate Bather Surveillance - Positioning, Number of Staff, Staff not Distracted {6-1.23(a)(4)-(7)}

Inspector Findings

lifeguard for north end was not on elevated chair; blind spot due to glare lifeguard cannot see bottom of pool in this position CORRECTED:  
lifeguard was repositioned to elevated chair

---

Additional Information Collected During Inspection

Free chlorine/bromine - 3.0 mg/L; PH - 7.6; Total alkalinity - 90 mg/L; Calcium hardness - 150 mg/L; Supervision level - IIb; Temporary Residence/Campground - No; Homeowner exemption - No;

Comments

---

END of REPORT

[Submit# 208948] VINCE'S PARK (ID 308515) Inspection# 1001839745