

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection -- Summary Report

Operation: SNED-ACRES WATER WELL #1 (ID: 308840)
Facility Name: SNED-ACRES FAMILY CAMPGROUND
Facility Code: 49-0197
Facility Address: 6590 SOUTH CAYUGA LAKE ROAD OVID, NY 14521

To the Attention of:

Sanitary Survey

Date: SEP 07, 2016 02:12 PM

Inspector: Thomas Scoles (tscoles@co.seneca.ny.us)

Responsible Person: Lynn Snedaker
(email:)

Summary

Number of public health hazards found: 0

Number of public health hazards NOT corrected:

Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Ground water under the direct influence of surface water; 4- Log Treatment installed - Yes; Coliform surveillance sample collected - No ;Chlorine residual - .09 mg/l, collection time 2:18 from office sink;

Comments

Total coliform sample collected, nitrate sample collected

END of REPORT

[Submit# 233168] SNED-ACRES WATER WELL #1 (ID 308840) Inspection# 1001871093