

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection -- Summary Report

Operation: SNED-ACRES FAMILY CAMPGROUNDS WATER WELL #2 (ID: 903331)
Facility Name: SNED-ACRES FAMILY CAMPGROUND
Facility Code: 49-0197
Facility Address: 6590 SOUTH CAYUGA LAKE ROAD OVID, NY 14521

To the Attention of:

Pre-op Inspection

Date: SEP 07, 2016 02:38 PM

Inspector: Thomas Scoles (tscoles@co.seneca.ny.us)

Responsible Person: Lynn Snedaker
(email:)

Summary

Number of public health hazards found: 0

Number of public health hazards NOT corrected:

Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

PUBLIC HEALTH HAZARD

VIOLATION OF 5-1.30(a) WAS OBSERVED. (# 7)

Part or parts of the violation item were observed to be in violation which were corrected at the time of inspection.

Code Requirements

5-1.30(a)(b) [ND] Disinfection of a groundwater source. CI and UV equipment is operating as designed. If UV is working, indicator light is On, intensity meter is >70%.

Inspector Findings

Public Health Hazard - no chlorine residual at bottom of distribution system, investigated pump house and found cl pump set to low, corrected

VIOLATION OF 5-1.30(g) WAS OBSERVED. (# 10)

All or parts of the violation item are IN violation.

Code Requirements

5-1.30(g) [NR] Maintain free chlorine residual at representative points in the distribution system.

Inspector Findings

Public Health Hazard - no chlorine residual at lot 101

Additional Information Collected During Inspection

Water System Information: Type of disinfection - Chlorination; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 2:40 pm, from lot 101; Chlorine residual - 0 mg/l, collection time 2:40 pm from lot 101;

Comments

discussed ability of emailing operation reports

END of REPORT

[Submit# 233165] SNED-ACRES FAMILY CAMPGROUNDS WATER WELL #2 (ID 903331) Inspection# 1001871094