

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection -- Summary Report

Operation: INTERLAKEN SPORTSMEN CLUB, INC. (ID: 732766)
Facility Name: INTERLAKEN SPORTSMEN CLUB, INC.
Facility Code: 49-9250
Facility Address: 8561 TUNISON ROAD INTERLAKEN, NY 14847

To the Attention of:

Sanitary Survey

Date: SEP 28, 2016 01:58 PM

Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)

Responsible Person: Jerry Smith

(email: yawslab@netzero.net)

Summary

Number of public health hazards found: 0

Number of public health hazards NOT corrected:

Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - None; Source Type - Not indicated; 4- Log Treatment installed - Not indicated; Coliform surveillance sample collected - No ;

Comments

Total Coliform water sample taken.

Nitrate water sample taken.

UV light was found at 61% efficiency. Interlaken Sportsman Club will service as soon as possible

END of REPORT

[Submit# 238722] INTERLAKEN SPORTSMEN CLUB, INC. (ID 732766) Inspection# 1001878378