

Seneca County Department of Health  
Environmental Services  
31 Thurber Drive , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us

## Public Water Supply Inspection -- Summary Report

Operation: Lodi Point State Park (ID: 308904 )  
Facility Name: Lodi Point State Park  
Facility Code: 4911818  
Facility Address: Lower Lake Road

To the Attention of:

### Sanitary Survey

Date: OCT 05, 2016 10:16 AM

Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)

Responsible Person: Stephen Garlick  
(email: )

### Summary

Number of public health hazards found: 0

Number of public health hazards NOT corrected:

Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

### Code Requirements

### Inspector Findings

---

### Additional Information Collected During Inspection

Water System Information: Type of disinfection - None; Source Type - Not indicated; 4- Log Treatment installed - Not indicated; Coliform surveillance sample collected - No ;

### Comments

Total Coliform water sample taken.  
Nitrate water sample taken.  
New line and pump installed from the well.  
New contact tank installed in June

---

END of REPORT

[Submit# 240386] Lodi Point State Park (ID 308904) Inspection# 1001880194