

Seneca County Department of Health  
Environmental Services  
31 Thurber Drive , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us

## Public Water Supply Inspection - Summary Report

Operation: Bellwether Hard Cider (ID: 499314 )  
Facility Name: bellwether hard cider  
Facility Code: 4930300  
Facility Address: 9070 Rt. 89 ROUTE Trumansburg, NY 14886

To the Attention of:  
William Barton  
63 woodcrest Ave.  
Ithaca , NY 14850-

### Sanitary Survey

Date: JAN 21, 2015 02:53 PM  
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)  
Responsible Person: William Barton (email: bill@cidery.com )

### Summary

Number of public health hazards found: 0  
Number of public health hazards NOT corrected:  
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

### Code Requirements

### Inspector Findings

### Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 3:00pm, from Utility room CWT; Chlorine residual - 0 mg/l, collection time 3:15pm from Utility CWT;

### Comments

Total Coliform water sample taken Utility CWT. Nitrate water sample taken Utility CWT. UV efficiency was at 68% efficiency. Advised to clean or change bulb immediately. Will be noted as a violation if present during next inspection.

END of REPORT

[Submit# 127489] Bellwether Hard Cider (ID 499314) Inspection# 1001637789