

Seneca County Department of Health  
Environmental Services  
31 Thurber Drive , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us  
Campground Inspection - Summary Report

Operation: WATERLOO HARBOR CAMPGROUND (ID: 308424 )  
Facility Name: WATERLOO HARBOR CAMPGROUND  
Facility Code: 49-0235  
Facility Address: 1278 WATERLOO-GENEVA ROAD WATERLOO, NY 13165

To the Attention of:  
NORBERT HAUSNER RIVERPARK COMMONS WATERLOO, LLC  
2099 RIDGE ROAD WEST  
ROCHESTER , NY 14626-

Inspection  
Date: MAY 22, 2014 02:46 PM  
Inspector: Thomas Scoles (tscoles@co.seneca.ny.us)  
Responsible Person: Justin Hausner (email: info@fuzzyguppies.com )

Summary  
Number of public health hazards found: 1  
Number of public health hazards NOT corrected: 0  
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

### PUBLIC HEALTH HAZARDS

A public health hazard is any condition that poses an imminent threat to the health or safety of the public. An owner/operator of a regulated facility must immediately correct all public health hazards or take actions to prevent exposure to the hazard.

#### ITEM # 7 WAS FOUND IN VIOLATION 1 TIME(S). PUBLIC HEALTH HAZARD

All or parts of the violation item are IN violation.

##### Code Requirements

Absence of cross connections - potable water supply {7-3.5(b)(1)(vii)}

##### Inspector Findings

hose bib vacuum breaker needed for dump station water hose.....main Rez tested in June 2013

##### Additional Information Collected During Inspection

##### Comments

---

END of REPORT

[Submit# 116152] WATERLOO HARBOR CAMPGROUND (ID 308424) Inspection# 1001541613