

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection - Summary Report

Operation: Americana Winery (ID: 308843)
Facility Name: americana winery
Facility Code: AG-01
Facility Address: East Covert Rd

To the Attention of:

Sanitary Survey

Date: MAR 17, 2015 12:41 PM
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)
Responsible Person: Joe Gober (email: wineinny@aol.com)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected:
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - Chlorination; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 12:35pm, from Cafe CWT; Chlorine residual - 0.39 mg/l, collection time 12:30pm from Cafe CWT;

Comments

Total Coliform water sample taken Cafe CWT. Nitrate Water samples taken Cafe CWT. Water system was to be in compliance with todays standards.

END of REPORT

[Submit# 130899] Americana Winery (ID 308843) Inspection# 1001651413