

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us
Public Water Supply Inspection - Summary Report

Operation: CAYUGA LAKE CREAMERY WATER SUPPLY (ID: 499244)
Facility Name: cayuga lake creamery
Facility Code: 49-9492
Facility Address: 8421 ROUTE 89 INTERLAKEN, NY 14847

To the Attention of:

Sanitary Survey

Date: APR 08, 2015 03:18 PM
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)
Responsible Person: Jeff Kostick (email: info@cayugalakecreamery.com)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected:
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - Chlorination; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 2:58pm, from Bathroom CWT; Chlorine residual - .38 mg/l, collection time 3:15pm from bathroom CWT;

Comments

Total Coliform water sample taken. Nitrate water sample taken. Well was evaluated and found in good condition.

END of REPORT

[Submit# 132373] CAYUGA LAKE CREAMERY WATER SUPPLY (ID 499244) Inspection# 1001653978