

Seneca County Department of Health  
Environmental Services  
31 Thurber Drive , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us

## Public Water Supply Inspection - Summary Report

Operation: Lakeview Mennonite School (ID: 530827 )  
Facility Name: lakeview mennonite school  
Facility Code: 4940005  
Facility Address: 4400 Seybolt ROAD Seneca Falls, NY 13148

To the Attention of:

### Sanitary Survey

Date: APR 14, 2015 02:04 PM  
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)  
Responsible Person: Ira Martin (email: )

### Summary

Number of public health hazards found: 0  
Number of public health hazards NOT corrected:  
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

### Code Requirements

### Inspector Findings

---

### Additional Information Collected During Inspection

Water System Information: Type of disinfection - None; Source Type - Not indicated; 4- Log Treatment installed - Not indicated; Coliform surveillance sample collected - No ;

### Comments

Total coliform water sample taken boys lav. Nitrate water sample taken boys lav. Extra bulb and sleeve on site. System was found in good condition. Well was evaluated and found in good condition.

---

END of REPORT

[Submit# 132639] Lakeview Mennonite School (ID 530827) Inspection# 1001654246