

Seneca County Department of Health  
Environmental Services  
31 Thurber Drive , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us

## Public Water Supply Inspection - Summary Report

Operation: Seneca Meadows Education Center (ID: 693239 )  
Facility Name: seneca meadows education center  
Facility Code: 49-4565  
Facility Address: 414 ROUTE Seneca Falls, NY 13148

To the Attention of:

### Sanitary Survey

Date: APR 22, 2015 02:12 PM  
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)  
Responsible Person: Richard Weis (email: )

### Summary

Number of public health hazards found: 0  
Number of public health hazards NOT corrected:  
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

### Code Requirements

### Inspector Findings

### Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 2:12am, from Classroom CWT; Chlorine residual - 0 mg/l, collection time 2:00pm from Classroom CWT;

### Comments

Total Coliform water sample taken Classroom CWT. Nitrate water sample taken Classroom CWT. Well was evaluated and found in good condition. Ultra Violet Disinfection system was found in good condition.

END of REPORT

[Submit# 133096] Seneca Meadows Education Center (ID 693239) Inspection# 1001654870