

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us
Campground Inspection - Summary Report

Operation: WELCOME TRAVELER CAMPGROUND (ID: 308426)
Facility Name: WELCOME TRAVELER CAMPGROUND
Facility Code: 49-0514
Facility Address: 672 PACKWOOD ROAD WATERLOO, NY 13165

To the Attention of:
MARGARET ANN WILLIAMS
PO BOX 182
WATERLOO , NY 13165-

Inspection
Date: MAY 14, 2015 04:57 PM
Inspector: Julie Hoster (jhoster@co.seneca.ny.us)
Responsible Person: owner unavailable (email:)

Summary
Number of public health hazards found: 0
Number of public health hazards NOT corrected: 0
Number of other violations found: 6

Each item found in violation is reported below along with the code requirement.

ITEM # 48 WAS FOUND IN VIOLATION 1 TIME(S).
All or parts of the violation item are IN violation.

Code Requirements

Toilet facilities - adequate, design - maintained

Inspector Findings

ITEM # 49 WAS FOUND IN VIOLATION 1 TIME(S).
All or parts of the violation item are IN violation.

Code Requirements

Toilet facilities - adequate number, distance, ratios, maintained

Inspector Findings

rest rooms were not available male/female both were without water due to a broken water line so therefore could not be used.

ITEM # 50 WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the violation item are IN violation.

Code Requirements

Handwash facilities - adequate number, location, maintained

Inspector Findings

ITEM # 51 WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the violation item are IN violation.

Code Requirements

Utility sinks - adequate, location, maintained

Inspector Findings

ITEM # 52 WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the violation item are IN violation.

Code Requirements

Showers (when provided) adequate, hot/cold water, maintained

Inspector Findings

showers not in working order due to water line break according to tenant

GENERAL

ITEM # 19 WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the violation item are IN violation.

Code Requirements

Adequate surface drainage {7-3.10(b)}

Inspector Findings

back lots are saturated on 05/19/2015

Additional Information Collected During Inspection

Comments

END of REPORT

[Submit# 134782] WELCOME TRAVELER CAMPGROUND (ID 308426) Inspection# 1001662486