

Seneca County Department of Health  
Environmental Services  
31 Thurber Drive , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us

## Public Water Supply Inspection - Summary Report

Operation: Eagle hotel (ID: 308162 )  
Facility Name: eagle hotel  
Facility Code: 49-AA26  
Facility Address: p.o. box 184 Iodi ny 14860

To the Attention of:

### Sanitary Survey

Date: JUN 10, 2015 01:12 PM  
Inspector: Melissa Brand (mbrand@co.seneca.ny.us)  
Responsible Person: Kirsten Jennings (email: )

### Summary

Number of public health hazards found: 0  
Number of public health hazards NOT corrected:  
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

## PUBLIC HEALTH HAZARD

### **VIOLATION OF 5-1.30(g) WAS OBSERVED. (# 10)**

Part or parts of the violation item were observed to be in violation which were corrected at the time of inspection.

#### Code Requirements

5-1.30(g) [NR] Maintain free chlorine residual at representative points in the distribution system.

#### Inspector Findings

Public Health Hazard - During time of inspection the pump was functioning. An air bubble was in the tubing that supplies chlorine to the system, this was not allowing the correct amount of chlorine to enter the system. This issue was corrected and the air bubble was removed so that the system was able to return to required performance standards. This is a continuing issue according to owner and needs to have a permanent solution.

#### Additional Information Collected During Inspection

Water System Information: Type of disinfection - Chlorination; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 1:05 pm, from Bar Sink CWT; Chlorine residual - .40 mg/l, collection time from ;

#### Comments

During inspection switching to UV system was discussed. Please contact this office to start the process and to get the correct information regarding switching to a UV system.

END of REPORT

[Submit# 136422] Eagle hotel (ID 308162) Inspection# 1001667746