

Seneca County Department of Health  
Environmental Services  
31 Thurber Drive , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us

## Public Water Supply Inspection - Summary Report

Operation: King's Garden Vineyard (ID: 663508 )  
Facility Name: king's garden vineyard  
Facility Code: 49-7444  
Facility Address: 9085 NYS 414 ROUTE Lodi, NY 14860

To the Attention of:  
Mike Oleksyn King's Garden Vineyard  
9085 Rt. 414  
Lodi , NY 14860-

Sanitary Survey  
Date: JUN 22, 2015 03:25 PM  
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)  
Responsible Person: melody ray (email: oleksyn.cor@gmail.com )

Summary  
Number of public health hazards found: 0  
Number of public health hazards NOT corrected:  
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

### Code Requirements

### Inspector Findings

### Additional Information Collected During Inspection

Water System Information: Type of disinfection - None; Source Type - Not indicated; 4- Log Treatment installed - Not indicated; Coliform surveillance sample collected - No ;

### Comments

Total Coliform water sample taken. Nitrate water sample taken. Well was evaluated and found in good condition. UV Disinfection system was functioning properly.

END of REPORT

[Submit# 137576] King's Garden Vineyard (ID 663508) Inspection# 1001670558