

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection - Summary Report

Operation: Triple J Campground (ID: 663577)
Facility Name: triple j rv park
Facility Code: 49-8982
Facility Address: 9411 BURDICK RD. INTERLAKEN, NY 14847

To the Attention of:

Sanitary Survey

Date: JUN 02, 2015 03:16 PM
Inspector: Melissa Brand (mbrand@co.seneca.ny.us)
Responsible Person: TO BE MAILED (email:)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected:
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - Chlorination; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 12:13 pm, from Site # 8; Chlorine residual - 2.13 mg/l, collection time from ;

Comments

Sample taken for T. coliform and Nitrate

END of REPORT

[Submit# 135780] Triple J Campground (ID 663577) Inspection# 1001665412