

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection - Summary Report

Operation: BUSY BEE MARKET AND CAFE WATER (ID: 308209)
Facility Name: busy bee market and cafe at kidder's
Facility Code: 49-AA47
Facility Address: 7930 COUNTY ROAD 153 INTERLAKEN, NY 14847

To the Attention of:

Sanitary Survey

Date: JUL 08, 2015 02:42 PM
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)
Responsible Person: Joseph D. Pinette (email:)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected:
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 1:48pm, from Handwash CWT; Chlorine residual - 0.00 mg/l, collection time 1:55pm from Handwash CWT;

Comments

Total Coliform water sample taken Hand-wash CWT. Nitrate water sample taken Hand-wash CWT. Facility is under the direct influence of surface water. Proper filtration to 1 micron-absolute was in place. Shore well was evaluated and found in good condition. UV system was inspected and found in good condition. Extra bulb and sleeve on-site.

END of REPORT

[Submit# 139604] BUSY BEE MARKET AND CAFE WATER (ID 308209) Inspection# 1001675585