

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection - Summary Report

Operation: Cayuga Ridge Winery (ID: 859102)
Facility Name: cayuga ridge winery
Facility Code: 49agmkt89
Facility Address: 89 ROUTE Ovid, NY 14521

To the Attention of:
Thomas Challen
6800 Rt 89
Ovid , NY 14521-

Sanitary Survey
Date: JUL 08, 2015 02:08 PM
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)
Responsible Person: Kay Adams (email:)

Summary
Number of public health hazards found: 0
Number of public health hazards NOT corrected:
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

PUBLIC HEALTH HAZARD

VIOLATION OF 5-1.71(a) WAS OBSERVED. (# 13)

Part or parts of the violation item were observed to be in violation which were corrected at the time of inspection.

Code Requirements

5-1.71(a) [SN] Exercise care and due diligence in the maintenance and/or supervision of all sources of water of the public water system to provide a water of a sufficient quantity and quality.

Inspector Findings

Public Health Hazard - Cayuga Ridge Winery and Estate has failed to maintain consistent quarterly water samples. Within the last 6 quarters Cayuga Ridge has sampled only 2 times. Seneca County Environmental Health has sampled 1 time while conducting a sanitary survey. Cayuga Ridge has missed 3 quarterly samples. Enforcement actions will be taken if 2 consecutive quarterly samples are missed.

VIOLATION OF 5-1.71(b) WAS OBSERVED. (# 14)

All or parts of the violation item are IN violation.

Code Requirements

5-1.71(b) [SO] Exercise care and due diligence in the operation and maintenance of a public water system

Inspector Findings

Public Health Hazard - Cayuga Ridge Winery and Estate is not sampling according to the established quarterly monitoring routine.

Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - No ;

Comments

Total Coliform water sample taken. Nitrate water sample taken. CL2 residual was 0.05mg/L.

END of REPORT

[Submit# 139612] Cayuga Ridge Winery (ID 859102) Inspection# 1001675581