

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection - Summary Report

Operation: Driftwood Inn (ID: 308198)
Facility Name: driftwood inn
Facility Code: 49-0627
Facility Address: 7401 WYERS POINT ROAD

To the Attention of:

Sanitary Survey

Date: JUL 28, 2015 03:00 PM
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)
Responsible Person: Jim Steuer (email: driftwood1946@gmail.com)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected:
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Not indicated; 4- Log Treatment installed - Yes; Coliform surveillance sample collected - Yes, collection time 2:45pm, from Kitchen CWT; Chlorine residual - .37 mg/l, collection time 2:35pm from kitchen CWT;

Comments

Nitrate water sample taken kitchen CWT. Total Coliform water sample taken kitchen CWT. UV and Chlorine system were functioning properly. Well was evaluated and found in good condition.

END of REPORT

[Submit# 143186] Driftwood Inn (ID 308198) Inspection# 1001683174