

Seneca County Department of Health  
Environmental Services  
31 Thurber Drive , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us

## Swimming Pool Inspection - Summary Report

Operation: Red Jacket Swimming Pool (ID: 308089 )  
Facility Name: RED JACKET YACHT CLUB  
Facility Code: 49-0351  
Facility Address: ROUTE 89 SENECA FALLS, NY 13148

To the Attention of:  
PAUL KOLB  
RED JACKET YACHT CLUB PO BOX 15  
SENECA FALLS , NY 13148-

### Inspection

Date: JUL 13, 2015 04:49 PM  
Inspector: Julie Hoster (jhoster@co.seneca.ny.us)  
Responsible Person: un available (email: )

### Summary

Number of public health hazards found: 0  
Number of public health hazards NOT corrected: 0  
Number of other violations found: 5  
Reinspection is required.

Each item found in violation is reported below along with the code requirement.

## GENERAL

ITEM # 50 WAS FOUND IN VIOLATION 1 TIME(s).

All or parts of the violation item are IN violation.

### Code Requirements

Bathhouse/Toilet Facilities Adequate, Clean, Ventilated, Warm Water, Soap, Hand Drying Facilities Provided, Refuse Storage, Disposal {6-1.14, 6-1.15}

### Inspector Findings

no soap in bath house showers

## POOL OPERATION, MAINTENANCE & SUPERVISION

ITEM # 23 WAS FOUND IN VIOLATION 1 TIME(s).

All or parts of the violation item are IN violation.

### Code Requirements

Lifesaving Equipment Adequate/Accessible, Lifeguard Chairs {6-1.23(b)}

### Inspector Findings

reaching pole is less than 15 ft long

## RECORDS/SIGNS

ITEM # 18 WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the violation item are IN violation.

Code Requirements

Pool Safety Plan Developed/Implemented/Updated {6-1.23(c)}

Inspector Findings

safety plan has not been revised regarding how reds jacket yacht club will indicate to campers that the lifeguard is on and when they are operating without a lifeguard

ITEM # 20 WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the violation item are IN violation.

Code Requirements

Regulations Posted - Capacity, Spa Warning, White Water Slide {6-1.24(c), 6-1.20(c), 6-1.25(e), 6-1.28(d)}

Inspector Findings

no capacity sign posted; no sign indicating hours of operation, glass containers prohibited, pollution of pool (expectorating, urinating, fecal matter, etc.) and proper slide usage

## SUPERVISION/STAFF

ITEM # 55 WAS FOUND IN VIOLATION 1 TIME(S).

Violation Item was not applicable/reviewed/evaluated/observed at the time of inspection.

Code Requirements

Qualified Supervision - Level I, Level II, Level III, Level IV {6-1.2(n), 6-1.23(a)(1)-(3), 6-1.23(a)(8), 6-1.23(a)(10)(ii), 6-1.31}

Inspector Findings

pump room locked sign states emergency phone in pump room; cell phones available on deck

Additional Information Collected During Inspection

Free chlorine/bromine - 2.0 mg/L; PH - 7.4; Total alkalinity - 100 mg/L; Calcium hardness - 80 mg/L; Supervision level - IV; Temporary Residence/Campground - Yes; Homeowner exemption - No;

Comments

inspection of pump room still needed

---

END of REPORT

[Submit# 141491] Red Jacket Swimming Pool (ID 308089) Inspection# 1001679904