

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us
Campground Inspection - Summary Report

Operation: SNED-ACRES FAMILY CAMPGROUNDS (ID: 308227)
Facility Name: SNED-ACRES FAMILY CAMPGROUND
Facility Code: 49-0197
Facility Address: 6590 SOUTH CAYUGA LAKE ROAD OVID, NY 14521

To the Attention of:
LYNN E SNEDAKER
6590 SOUTH CAYUGA LAKE ROAD
OVID , NY 14521-

Inspection
Date: JUL 07, 2015 01:11 PM
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)
Responsible Person: Lynn Snedaker (email:)

Summary
Number of public health hazards found: 0
Number of public health hazards NOT corrected: 0
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Comments

Cl2 residuals found within the distribution system. .33mg/L at furthest spigot.

END of REPORT

[Submit# 139340] SNED-ACRES FAMILY CAMPGROUNDS (ID 308227) Inspection# 1001675095