

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection - Summary Report

Operation: SNED-ACRES WATER (ID: 308840)
Facility Name: sned-acres family campground
Facility Code: 49-0197
Facility Address: 6590 SOUTH CAYUGA LAKE ROAD OVID, NY 14521

To the Attention of:

Sanitary Survey

Date: JUL 07, 2015 01:16 PM
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)
Responsible Person: Lynn Snedaker (email: info@sned-acre.com)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected:
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Ground water under the direct influence of surface water; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 12:30pm, from bathhouse CWT; Chlorine residual - .33 mg/l, collection time 1:00pm from spigot;

Comments

Total Coliform water sample taken. Nitrate water sample taken. Extra bulb and sleeve on site.

END of REPORT

[Submit# 139339] SNED-ACRES WATER (ID 308840) Inspection# 1001675018