

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection - Summary Report

Operation: Sunset-on-Seneca Campground (ID: 308168)
Facility Name: sunset-on-seneca campsites
Facility Code: 49-0488
Facility Address: 8449 LOWER LAKE ROAD

To the Attention of:

Sanitary Survey

Date: JUL 21, 2015 02:10 PM
Inspector: Melissa Brand (mbrand@co.seneca.ny.us)
Responsible Person: to be mailed (email:)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected:
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 1:55, from kitchen cwt; Chlorine residual - 0.0 mg/l, collection time from ;

Comments

Sample taken for t.coliform and nitrate analysis.

END of REPORT

[Submit# 142140] Sunset-on-Seneca Campground (ID 308168) Inspection# 1001680970